

**ENVIRONMENTAL HEALTH**  
 Onsite Water Protection Notices of Violation  
 October 2014

NOV DATE	SUBJECT PROPERTY ADDRESS	TYPE OF VIOLATION	NOV EXPIRATION DATE	FORWARDED TO CO. ATTY?	COMPLIANCE STATUS (YES/NO)	COMPLIANCE DATE	NOTES
11/26/2013	3823 Hanford Dr	Illicit Straight Pipe	12/26/2013	Y	N		12/6/2013 House was previously unoccupied. Mr. Durham has moved back in. He has been made aware of the straight pipe, informed to keep the tanks pumped until the issue is resolved and instructed to pursue a discharging permit with DWR. 6/2/2014 - House remains occupied, verified by site visit. NOV forwarded to County Attorney's Office.
3/14/2013	2707 Little River Dr	Surface discharge of effluent	4/14/2013	Y	N		Application for repair permit has been received, Met septic contractor onsite 3/12/13. System determined to be non-repairable. New NOV issued directing property owner to pursue permit for discharging system through NC DWQ. 9/30/13 - No application has been received by NC DWR. 2/3/2014 - Site visit verified system is still failing. 3/5/2014 - NOV forwarded to County Attorney's office. 3/27/2014 - Owner contacted NC DWR regarding application for discharging permit. 6/2/14 - Verified with DWR that owner has applied, hired and engineer, and is moving forward with the permit process. DWR contacted for status update, awaiting reply 8/4/2014. System design has been approved and a construction authorization has been issued by NC DWR.
3/12/2014	7001 Herndon Rd	Surface discharge of effluent	4/10/2014	N	N		3/10/2014 - Site visit, confirmed surfacing effluent. Municipal sewer available. 6/1/14 Owner has applied for sewer connection and is awaiting tap installation. Property has completed the annexation process.
3/20/2014	913 Cartman	Surface discharge of effluent onto neighbor's yard	4/20/2014	Y	N		3/20/2014 - The complaint is valid. Issued NOV 4/29/2014 - Return visit made by EH, course of action to remedy failure communicated to owner. NOV forwarded to County Attorney's office 8/14/2014
4/17/2014	5430 Lake Vista	Back-up of sewage into septic tank	7/17/2014	N	N		Property owners contacted Env. Health for repair evaluation. Parcel does not have sufficient available space for a repair drainfield. Referred owners to NC DWR for NPDES permit. CA has been issued by DWR.
4/29/2014	5677 Kemp	Surface Discharge of effluent	6/29/2014	Y	N		Sewage is ponding over the drainfield. Landscape position has been changed to a toe slope due to significant imported fill. System is serving an office and 2 bedroom trailer, but is permitted only for the office. 5/29/2014 - Owner is deceased. 30 day extension for NOV granted at the request of estate executor. NOV forwarded to Coutny Attorney's office 8/14/2014.

6/9/2014	4324 Trenton Rd	No Subsurface Operator	7/9/2014	Y	N	No Subsurface Operator. NOV forwarded to County Attorney's office 8/14/2014.
6/11/2014	209 Bacon	Collapsed Tank	7/11/2014	Y	N	Collapsed septic tank. NOV forwarded to County Attorney's office 8/14/2014. Has undergone change of ownership, no longer bank owned.
7/31/2014	3629 Freeman	Backing up and ponding over septic tank	9/1/2014	N	N	Failing septic system. Non-repairable. Owner is attempting to gain access to municipal sewer line. City Council approved sewer connection on October 6 2014. Property owners are working with the City to facilitate the connection.
8/28/2014	310 N Mineral Spring	Surface Discharge of effluent	9/29/2014	Y	Y	Sewage discharging due to nonoperational lift pump. House is connected to municipal sewer but is outside the City limits. Forwarded to County Attorney's office 10/20/2014. 10 day demand letter mailed to owner by County Attorney's office 10/30/2014.
9/24/2014	5000 Glenn	No Subsurface Operator	10/24/2014	N	N	No subsurface wastewater system operator
9/24/2014	7814 Kennebec Dr	No Subsurface Operator	10/24/2014	N	N	No subsurface wastewater system operator