

ENVIRONMENTAL HEALTH
Onsite Water Protection Notices of Violation
December 2014

NOV DATE	SUBJECT PROPERTY ADDRESS	TYPE OF VIOLATION	NOV EXPIRATION DATE	FORWARDED TO CO. ATTY?	COMPLIANCE STATUS (YES/NO)	COMPLIANCE DATE	NOTES
11/26/2013	3823 Hanford Dr	Illicit Straight Pipe	12/26/2013	Y	N		12/6/2013 House was previously unoccupied. Mr. Durham has moved back in. He has been made aware of the straight pipe, informed to keep the tanks pumped until the issue is resolved and instructed to pursue a discharging permit with DWR. 6/2/2014 - House remains occupied, verified by site visit. NOV forwarded to County Attorney's Office.
3/12/2014	7001 Herndon Rd	Surface discharge of effluent	4/10/2014	N	N		3/10/2014 - Site visit, confirmed surfacing effluent. Municipal sewer available. 6/1/14 Owner has applied for sewer connection and is awaiting tap installation. Property has completed the annexation process.
3/20/2014	913 Cartman	Surface discharge of effluent onto neighbor's yard	4/20/2014	Y	N		3/20/2014 - The complaint is valid. Issued NOV 4/29/2014 - Return visit made by EH, course of action to remedy failure communicated to owner. NOV forwarded to County Attorney's office 8/14/2014
4/29/2014	5677 Kemp	Surface Discharge of effluent	6/29/2014	Y	N		Sewage is ponding over the drainfield. Landscape position has been changed to a toe slope due to significant imported fill. System is serving an office and 2 bedroom trailer, but is permitted only for the office. 5/29/2014 - Owner is deceased. 30 day extension for NOV granted at the request of estate executor. NOV forwarded to Coutny Attorney's office 8/14/2014.
6/9/2014	4324 Trenton Rd	No Subsurface Operator	7/9/2014	Y	N		No Subsurface Operator. NOV forwarded to County Attorney's office 8/14/2014.
6/11/2014	209 Bacon	Collapsed Tank	7/11/2014	Y	N		Collapsed septic tank. NOV forwarded to County Attorney's office 8/14/2014. Has undergone change of ownership, no longer bank owned.
7/31/2014	3629 Freeman	Backing up and ponding over septic tank	9/1/2014	N	N		Failing septic system. Non-repairable. Owner is attempting to gain access to municipal sewer line. City Council approved sewer connection on October 6 2014. Property owners are working with the City to facilitate the connection. Sewage discharging due to nonoperational lift pump. House is connected to municipal sewer but is outside the City limits. Forwarded to County Attorney's office 10/20/2014. 10 day demand letter mailed to owner by County Attorney's office 10/30/2014.
8/28/2014	310 N Mineral Spring	Surface Discharge of effluent	9/29/2014	Y	Y		
9/24/2014	5000 Glenn	No Subsurface Operator	10/24/2014	N	N		No subsurface wastewater system operator

11/6/2014	2800 Ferrand	Surface Discharge of effluent & building addition over septic tanks	12/6/2014	N	N		Surface discharge of effluent. An unapproved two-story deck addition previously built over septic tanks. Lot is non-repairable, municipal sewer is available.
11/10/2014	2810 Old Oxford Hwy	Surface discharge of effluent	12/10/2014	N	N		Surface discharge of effluent. Repair permit issued for a replacement system.
12/17/2014	3500 Interworth	Surface discharge of effluent	1/19/2014	N	N		Discharging via a culvert pipe
12/17/2014	5126 Leesville Rd	Collapsing septic tank	1/19/2014	N	N		Collapsed septic tank.
12/23/2014	1013 Variform	Effluent discharging to ground surface	1/23/2014	N	N		Failing LPP
1/23/2014	402 Mare	Effluent discharging to ground surface	1/23/2014	N	N		Failing at the first dam.
1/23/2014	18 Thistle Trace	Effluent backing up	1/23/2014	N	N		Control panel does not work
12/31/2014	4129 Guess Rd	Septic tank structurally unsound, building addition over septic tanks	1/31/2015	N	N		Heavy root intrusion in tank, deck footing on tank, probable unpermitted gravel conventional line added at some point, sandfilter on property
12/12/2014	1313 Olive Branch	Surfacing effluent, system crosses property lines	1/12/2015	N	N		System is surfacing effluent, drainfield totally saturated. Also crosses property lines; repair permit issued and easement recorded, have had preconstruction, will issue CA soon.
12/11/2014	1723 Bahama	Cracked septic tank	1/11/2015	N	Y	12/16/2014	Tank has been replaced, 12/16/14
12/10/2014	2612 Cooksbury	Sewer disconnection	1/10/2015	N	N		Sewer disconnected
12/10/2014	1044 Lakeside Dr	Washline discharge to ground surface	1/10/2015	N	N		Washline is now plumbed directly to ground surface, not into d-box for washline.
12/18/2014	2109 Winkler Rd	Unpermitted expansion of bedrooms in house, building addition over septic tanks	1/18/2015	N	N		Building foundation is partially on septic tank, at some point a bedroom was added to the house; system is currently for 2 br. SFD. Expansion permit has been issued for 3br Controlled Demonstration Low Profile system